



TYPE 'A' BLOWOFF- FOR MAINS  
36" AND LARGER

NOTES:

1. RESTRAIN ALL JOINT ON 6" WATER, WITH MECH. JOINT RETAINER GLANDS SEE STANDARD DETAIL B/2.04
2. SET ALL VALVES AND MANHOLE RIM TO FINISHED GRADE OR AS SHOWN ON CONTRACT DRAWINGS.
3. TANGENTIAL OUTLET IS TO BE USED WHEN WATER MAIN IS OTHER THAN D.I. PIPE.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

*[Signature]* 6/29/95  
DIRECTOR OF DEVELOPMENT SERVICES DATE  
*[Signature]* 6/29/95  
WATER / SEWER ENGINEER DATE

STANDARD DETAIL

TYPE "A" BLOW OFF  
FOR MAINS 36" AND  
LARGER

REVISIONS:

W

5.02